

AMENDMENT OF SOLICITATION

Page of Pages

1 / 2

1. AMENDMENT/MODIFICATION NO. 0002		2. EFFECTIVE DATE AUG 23, 2003	
3. ISSUED BY DEPARTMENT OF THE ARMY, BALTIMORE DISTRICT CORPS OF ENGINEERS P.O. BOX 1715 BALTIMORE, MARYLAND 21203-1715 CODE: _____			
4. NAME AND ADDRESS OF CONTRACTOR (Name, street, county, State and ZIP Code)		4A. AMENDMENT OF SOLICITATION NO. W912DR-04-B-0018 4B. DATED (SEE ITEM 5) AUG 02, 2004	
5. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ____ is extended, X is not extended. BID OPENING 2:00 PM, Local Time SEP 02, 2004 Others must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 4 and 8, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of the amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.			
6. ACCOUNTING AND APPROPRIATION DATA (If required) GATED SPILLWAY ELECTRICAL AND CONTROL UPGRADE, RAYSTOWN LAKE, PA			
7. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <u>SPECIFICATIONS:</u> (1) Section 11287 Page 2, Paragraph 2.1: Make the following changes: (a) In the first sentence change the wording "Electrical equipment, motors, motor efficiencies, and wiring..." to read "Electrical equipment and wiring...". (b) In the second sentence change the wording "Motors shall be of the high efficiency type and..." to read "Motors shall be of the design "C" type, with 225% locked rotor torque as a percentage of full load torque and...". <u>DRAWINGS:</u> (2) <u>Plate 6:</u> Add humidity sensor next to the thermostat adjacent to dehumidifier, in accordance with sketch SK-1, dated August 17, 2004. Except as provided herein, all terms and conditions of the document referenced in Item 4A, as heretofore changed, remains unchanged and in full force.			
8. NAME AND TITLE OF SIGNER (Type or print)		9. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	10. DATE SIGNED


(3) Plate 7: Relocate reheat coil in dehumidifier unit upstream of the fan, in accordance with sketch SK-2, dated August 17, 2004. Note that any arrangement of a packaged factory fabricated dehumidifier that meets the scheduled performance criteria will be acceptable.

(4) Plate 7: Add the following Sequence of Operations note in accordance with sketch SK-3, dated August 17, 2004.

"Generator Discharge: When the generator is off, all dampers shall be closed. When the generator starts, the recirculation damper shall open and the intake and discharge dampers shall remain closed. When the generator room temperature reaches 80 degrees Fahrenheit on rise, the intake and discharge dampers shall open. After the intake and discharge dampers reach the full open position, the recirculation damper shall close. When the generator room temperature reaches 65 degrees Fahrenheit on fall, the recirculation damper shall open. After the recirculation damper reaches the full open position, the intake and discharge dampers shall close. When the generator is de-energized, all dampers shall return to the fully closed position."

ATTACHMENTS:

1) Sketches SK-1, SK-2, and SK-3, dated August 17, 2004.



GATED SPILLWAY UPGRADE – RAYSTOWN

SK-1


PLATE 6

17 AUGUST 2004

EAC, P.C.

9004-B CROWNWOOD COURT, BURKE, VA 22015

TEL. (703) 978-0923



GATED SPILLWAY UPGRADE – RAYSTOWN

SK-2

PLATE 7

17 AUGUST 2004

EAC, P.C.

9004-B CROWNWOOD COURT, BURKE, VA 22015

TEL. (703) 978-0923

VENTILATION SYSTEM

THE VENTILATION SYSTEM SHALL OPERATE EVERY 6 HOURS FOR 15 MINS. THE INTAKE DAMPER SHALL OPEN AND BOTH THE INTAKE AND VENTILATION FANS SHALL START. ELECTRIC DUCT HEATER SHALL TURN ON UPON A TEMPERATURE BELOW 50°F.



GENERATOR DISCHARGE AIR

WHEN THE GENERATOR IS OFF, ALL DAMPERS SHALL BE CLOSED. WHEN THE GENERATOR STARTS, THE RECIRCULATION DAMPER SHALL OPEN AND THE INTAKE AND DISCHARGE DAMPERS SHALL REMAIN CLOSED. WHEN THE GENERATOR ROOM TEMPERATURE REACHES 80 DEGREES FAHRENHEIT ON RISE, THE INTAKE AND DISCHARGE DAMPERS SHALL OPEN. AFTER THE INTAKE AND DISCHARGE DAMPERS REACH THE FULL OPEN POSITION, THE RECIRCULATION DAMPER SHALL CLOSE. WHEN THE GENERATOR ROOM TEMPERATURE REACHES 65 DEGREES FAHRENHEIT ON FALL, THE RECIRCULATION DAMPER SHALL OPEN. AFTER THE RECIRCULATION DAMPER REACHES THE FULL OPEN POSITION, THE INTAKE AND DISCHARGE DAMPERS SHALL CLOSE. WHEN THE GENERATOR IS DE-ENERGIZED, ALL DAMPERS SHALL RETURN TO THE FULLY CLOSED POSITION.

FOR
SEE IN [

EXHAUST FAN SCHEDULE

MARK	TYPE	CFM	ESP (IN)	RPM	ELECTRICAL [
					BHP	HP	V/
EF-1	BD	2000	0.125	785	0.19	0.25	120
VF-2	BD	400	0.125	-	0.086	0.25	120

NOTE: 1. DD = DIRECT DRIVE, BD = BELT DRIVE

GATED SPILLWAY UPGRADE – RAYSTOWN

SK-3	PLATE 7	17 AUGUST 2004
EAC, P.C.	9004-B CROWNWOOD COURT, BURKE, VA 22015	TEL. (703) 978-0923